



PIMPRI CHINCHWAD MUNICIPAL CORPORATION
E ZONE, BHOSARI — 411 039

No. E/Health/5/WS/146/2026

Date:-10/09/2026

"Safe drinking water and sanitary condition certificate"

It is certified that an inspection team headed by "Health Department" of Assistant Commissioner, E Zone Health Department, Pimpri Chinchwad Municipal Corporation, Bhosari -411039, inspected "Sayajinath Maharaj School", situated at Wadmukhwadi, Bhosari Phata, Alandi Road, Pune-412105, checked the water test reports, submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building and the campus as per the norms prescribed by the State government norms.

The above certificate is valid for a period of one year from the date of issue..




Zonal Officer

E Zone Office

Pimpri Chinchwad Municipal Corporation



SSAS LABORATORY

(FORMERLY SHREE SIDDHIVINAYAK AQUA SOLUTIONS LLP)

NABL ACCREDITED LABORATORY

TEST REPORT



TC-15217

Report No/ULR No : TC152172600000938F Sample Code No : SSAS/2026/09/0938
Sample Receipt Date : 03.09.2026 Sample Description : Water
Analysis Start Date : 03.09.2026 to 07.09.2026 Sample Condition : Satisfactory
Date of Report Issue : 07.09.2026 Sample Type & Qty : Water Sample, 1 lit
Sample Marked As : Drinking Water

Issued to: SAYAJI NATH MAHARAJ SCHOOL

Alandi Rd, Laxmi-Narayan Nagar, Wadmutkhadi, Charholi Budruk, Pimpri-Chinchwad, 412105

Sl. No	PARAMETER TESTED	UNITS	RESULT	IS: 10500-2012 (Second Revision)	TEST METHOD
PHYSICO-CHEMICAL				Requirement (Acceptable Limit)	
1.	Odour	-	Agreeable	Agreeable	IS: 3025 Part-05, 2018.
2.	Turbidity	NTU	< 0.1	Max 1	IS: 3025 Part-10, 2023
3.	pH value	-	7.63	6.5-8.5	IS: 3025 Part-11, 2022
4.	Total Dissolved Solids	mg/l	102	Max 500	IS: 3025 Part-16, 2023
5.	Total Hardness as CaCO ₃	mg/l	56.3	Max 200	IS: 3025 Part-21, 2009
6.	Calcium as Ca++	mg/l	27.8	Max 75	IS: 3025 Part-40, 1991
7.	Magnesium as Mg ++	mg/l	4.6	Max 30	IS: 3025 Part-46, 2022
8.	Total Alkalinity as CaCO ₃	mg/l	28.9	Max 200	IS: 3025 Part- 23, 2023
9.	Chloride as Cl-	mg/l	8.4	Max 250	IS: 3025 Part- 32, 1988
10.	Free Residual Chlorine	mg/l	< 0.2	0.2 #	IS: 3025 Part - 26, 2021
11.	Sulphate as SO ₄	mg/l	0.8	Max 200	IS: 3025 Part- 32, 1986



+91 9561889433



www.ssaslab.com
contact@ssaslab.com



Shree Siddhivinayak, Raj Vihar Society
Undri, Pune 411060



SSAS LABORATORY

(FORMERLY SHREE SIDDHIVINAYAK AQUA SOLUTIONS LLP)

NABL ACCREDITED LABORATORY

TEST REPORT

Report No/ULR No : SSAS202609070938 Sample Code No : SSAS/2026/09/0938
Sample Receipt Date : 03.09.2026 Sample Description : Water
Analysis Start Date : 03.09.2026 to 07.09.2026 Sample Condition : Satisfactory
Date of Report Issue : 07.09.2026 Sample Type & Qty : Water Sample, 1 lit
Sample Marked As : Drinking water

Issued to: SAYAJI NATH MAHARAJ SCHOOL

Alandi Rd, Laxmi-Narayan Nagar, Wadmukhwadi, Charholi Budruk, Pimpri-Chinchwad, 412105

Sr. No	Parameters Tested	Units	Results	IS: 10500-2012 (Second Revision)	Test Method
				Requirement (Acceptable Limits)	
BACTERIOLOGICAL					
12	Total Coliform (MPN/100ml).	-	Not Detected	Shall not be detectable in any 100 ml sample	IS: 1622, 1981
13	Faecal Coliform (MPN/100ml)	-	Not Detected	Shall not be detectable in any 100 ml sample	IS: 1622, 1981
14	E. coli in 100 ml of sample	-	Absent	Shall not be detectable in any 100 ml sample	IS: 1622, 1981

Remarks: 1) The above water sample Fit For Drinking Purpose to IS: 10500-2012 (Second Revision) Drinking Water Specification with respect to the test conducted.
2) The results relate to parameters tested.

Note:

- # To be applicable only when water is chlorinated. Minimum 0.2 mg/l
- Test results are applicable to the sample/s tested as per Job ID only.
- Contents of this report are meant for your guidance & should not be used for advertisement, evidence or litigation.
- This report, shall not be reproduce in full or part, shall not be published, advertised, without the written approval of SSAS Laboratory.
- Total Liability of our Institution is limited to the Invoice Amount / Testing Charges.
- SSAS Laboratories is not responsible for the authenticity of photocopied or scanned reports.
- Subject to Pune Jurisdiction

Review By
Mr. Dattatray D
QM



Authorised Signatory
Mr Vishal Doke
TM



+91 9561889433



www.ssaslab.com
contact@ssaslab.com



Shree Siddhivinayak, Raj Vihar Society
Undri, Pune 411060